

## Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

### PHD Mfg Inc, Pipe Hangers

<b>Product Designation</b>	<b>Hanger Rod Size, in. (mm)</b>	<b>Component Description</b>	<b>For Nominal Pipe Sizes, in.</b>
36	3/8 (10)	Offset Steel Eye Socket	3/4 through 4
37	3/8 (10)	Offset Steel Eye Socket	3/4 through 4
141	3/8 (10)	Swivel Ring Loop Hanger	3/4 through 4
141	1/2 (12)	Swivel Ring Loop Hanger	5 through 8
151	1/2 (12)	Swivel Ring Loop Hanger	2 1/2 through 3 1/2
151	5/8 (16)	Swivel Ring Loop Hanger	4, 5
151	3/4 (20)	Swivel Ring Loop Hanger	6
151	3/4 (20)	Swivel Ring Loop Hanger	8
253/250	3/8 (10)	Pressed Steel C-Clamp	3/4 through 4
290	3/8 (10)	Purlin Clamp	3/4 through 4
345#	3/8 (10)	Top Beam Clamp	3/4 through 4
353/350	3/8 (10)	Spartan Top Beam C-Clamp	3/4 through 4
354/370/350	1/2 (12)	Spartan Top Beam C-Clamp	5 through 8
363/360	3/8 (10)	Spartan Top Beam C-Clamp	3/4 through 4
364/360	1/2 (12)	Spartan Top Beam C-Clamp	5 through 8
425††/426††/450/451*/453**/454†	1/2 (12)	Clevis Hanger	2 1/2 through 3 1/2

425††/426††/450/451*/453**/454†	5/8 (16)	Clevis Hanger	4, 5
450/451*/453**/454†	3/4 (20)	Clevis Hanger	6
450/451*/453**/454†	3/4 (20)	Clevis Hanger	8
550/551	n/a	Riser Clamp	3/4 through 8
906	3/8 (10)	Steel Side Beam Connector	3/4 through 4
907	3/8 (10)	Side Beam Bracket	3/4 through 4
908	3/8 (10)	Side Beam Connector	3/4 through 4

\*Electro-Galv. Finish, \*\* PVC coated, † Hot-dip galvanized, # FM Approved for use in the top beam position only. †† Stainless Steel

<b>Company Name:</b>	PHD Mfg Inc
<b>Company Address:</b>	44018 Columbiana-Waterford Rd, Columbiana, Ohio 44408-9481, USA
<b>Company Website:</b>	<a href="http://www.phd-mfg.com/">http://www.phd-mfg.com/</a>
<b>New/Updated Product Listing:</b>	No
<b>Listing Country:</b>	United States of America
<b>Certification Type:</b>	FM Approved