



# VFXT7.EX2833 - HANGERS, PIPE CERTIFIED FOR CANADA

## Hangers, Pipe Certified for Canada

See General Information for Hangers, Pipe Certified for Canada

### P H D MFG INC

44018 COLUMBIANA WATERFORD RD  
COLUMBIANA, OH 44408-9481 USA

### Pipe hangers

EX2833

Model	Hanger Type	Rod Size, mm	NPS*	Comments
141	Band Hanger	3/8	3/4, 1, 1-1/4, 1-1/2, 2	For use with 3/8" Total Captive
141	Band Hanger	3/8	2-1/2, 3, 3-1/2, 4	—
141	Band Hanger	1/2, 12 mm	5, 6, 8	—
055	Surge Device	3/8	3/4, 1, 1-1/4, 1-1/2, 2	To be used with the Model 141 Band Hanger
353/350	Universal Beam Clamp	10 (3/8 in.)	Up to 4	—
345	Top Beam Clamp	3/8	Up to 4	—
354/370/350	Top Beam Clamp	12 (1/2 in)	Up to 8	—
355/374/350	Top Beam Clamp	5/8	Up to 8	—
356/350	Top Beam Clamp	3/4	Up to 8	—
357/350	Top Beam Clamp	7/8	Up to 8	—
363/360	Top Beam Clamp	10 (3/8 in.)	Up to 4	—
364/360	Top Beam Clamp	12 (1/2 in)	Up to 8	—

450	Clevis Hanger	5/8	4	—
451	Clevis Hanger	5/8	4	—
453	Clevis Hanger	5/8	4	—
454	Clevis Hanger	5/8	4	—
36	Offset Eye Socket	10 (3/8 in.)	Up to 2	3/8 x 2-1/2 in. lag Screw
36	Offset Eye Socket	10 (3/8 in.)	Up to 4	3/8 bolt
37	Offset Eye Socket	3/8	Up to 2	#16x2 in. wood drive screws
37	Offset Eye Socket	3/8	Up to 4	—
37	Eye Socket	1/2	Up to 8	This device is not offset
906	Side Beam Connector	3/8	Up to 2	#16x2 in. wood drive screws
906	Side Beam Connector	3/8	Up to 4	1/2 x 2-1/2 in. lag Screw
940	Ceiling Flange	3/8	Up to 2	—
940-S	Ceiling Flange	3/8	Up to 2	—
945	Ceiling Flange	3/8	Up to 2	—
040	Pipe Clamp	10 (3/8 in)	3/4, 1, 1-1/4, 1-1/2, 2	—
040	Pipe Clamp	12 (1/2 in)	2-1/2, 3, 3-1/2	—
040	Pipe Clamp	16 (5/8 in)	4, 5	—
040	Pipe Clamp	19 (3/4 in)	6	—
040	Pipe Clamp	22 (7/8 in)	8	—
020	Swivel Attachment	3/8	Up to 4	—

990	In-Rack	10 (3/8)	4	Installed in flue spaces between pallet racks with "Tear Drop" or "Interlake New style" rack columns.
358	Retaining Strap	—	Up to 8	Lengths: 4-1/2, 6, 8, 10, 12, 14 in.
359	Retaining Strap	—	Up to 8	Lengths: 4-1/2, 6, 8, 10, 12, 14 in.

\* NPS = Nominal pipe size

Last Updated on 2017-07-17

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"