

VIXH7.EX15518 - SUPPORT DEVICES FOR THERMOPLASTIC SPRINKLER PIPING CERTIFIED FOR CANADA

Support Devices for Thermoplastic Sprinkler Piping Certified for Canada

See General Information for Support Devices for Thermoplastic Sprinkler Piping Certified for Canada

P H D MFG INC

44018 COLUMBIANA WATERFORD RD
COLUMBIANA, OH 44408-9481 USA

EX15518

Pipe Hanger:

Model	Pipe Type	Hanger Type	NPS*	Comments
070	CPVC	Two Hole Strap Hanger	3/4, 1, 1-1/4, 1-1/2, 2	Side beam and bottom beam installation
075	CPVC	Wraparound One-Hole Strap	3/4, 1, 1-1/4, 1-1/2, 2	Side beam installation
076	CPVC	Standoff	3/4, 1, 1-1/4, 1-1/2, 2	Side beam and bottom beam installation
077	CPVC	Side Mount	3/4, 1, 1-1/4, 1-1/2, 2	Side beam and bottom beam installation
141	CPVC	Band Hanger	3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	—

Surge Device:

Model	Pipe Type	Hanger Type	NPS*	Comments
070	CPVC	Two Hole Strap Hanger	3/4, 1, 1-1/4, 1-1/2, 2	Top Beam Installation
077	CPVC	Side Mount	3/4, 1, 1-1/4, 1-1/2, 2	Top Beam Installation

* NPS - Nominal pipe size

Last Updated on 2011-03-28

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"