CLAMPING PIPE ATTACHMENT

FIG. 031

Designed for bracing pipe against sway and seismic disturbance. Versatile design allows for attachment at any

angle and the ability to be used in a lateral or longitudinal bracing configuration. The pipe attachment

component of a sway brace system used in conjunction with a PHD Manufacturing structural attachment fitting and joined together with a bracing element form a complete sway brace assembly. Sway brace assemblies are

SEISMIC BRACING

intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions. Pipe sizes 2" thru 8". Can use 1" thru 2" SCH 40 pipe, structural steel, and PHD 12 gauge strut channel

(1001 & 1201) as sway bracing elements.

Material: Ductile iron and carbon steel.

Finish: Electro-galvanized

Size:

Install: Place attachment around pipe to be braced, positioning brace attachment as needed, then tighten clamping bolts and

nuts finger tight. Insert brace component into fitting against back of jaw. Tighten set screw finger tight, adjust brace angle as needed, then tighten set screw until hex head breaks off. Then evenly torque clamping bolts until hex portion

of clamping nuts break off.

Approvals: Underwriters Laboratories listed for US and Canada and Factory Mutual approved. Listed for use with PHD

sway brace components only.

Ordering: Specify figure number and sprinkler pipe size.

	UL Maximum Design Loads										
All Pipe Sizes, SCH 10 & 40 (31/2 SCH 40 only) Lateral & Longitudinal Assemblies											
Brace Member	Member Thickness	Member Length	lbs.	kN							
1" Thru 2" Pipe	SCH 40	Refer to NFPA13	1370	(6.09)							
Structural Steel	1/4" & 3/8" thick	Refer to NFPA13	1370	(6.09)							
1001 Series Strut	12 Ga.	See Chart Below	1370	(6.09)							
1201 Series Strut	12 Ga.	See Chart Below	1370	(6.09)							

UL's current Listings, shown above, are predicated on installation in accordance with the latest edition of NFPA 13. The 2016 and earlier editions of NFPA 13 referenced a minimum safety of 1.5 for the load rating as compared to 2.2 for the current edition.

The load ratings noted in table below, Previously Listed Loads, are consistent with the historical cULus Listings that were evaluated to the requirements of UL 203A, Outline of Investigation for Sway Brace Devices for Fire Sprinkler System Piping, based upon a minimum safety factor of 1.5 in accordance with the earlier editions of NFPA 13. The load ratings based upon the 2016 or earlier editions of NFPA 13 should only be used where approved by the Authority Having Jurisdiction (AHJ).

Previously Listed UL Loads										
All Pipe Sizes, SCH 10 & 40 (31/2 SCH 40 only) Lateral & Longitudinal Assemblies										
Brace Member Member Thickness Member Length Ibs. kN										
1" Thru 2" Pipe	SCH 40	Refer to NFPA13	*2015	*(8.96)						
Structural Steel	1/4" & 3/8" thick	Refer to NFPA13	*2015	*(8.96)						
1001 Series Strut	12 Ga.	See Chart Below	*2015	*(8.96)						
1201 Series Strut	12 Ga.	See Chart Below	*2015	*(8.96)						

*Load ratings are based on a minimum safety factor of 1.5 in accordance with NFPA 13-2016 Section A.9.3.5.2.3.

	FM Maximum Design Load (All Sizes)										
For Bracing SCH 10, 40 & Flow Pipe											
Brace	e Member	Direction	Brace Angle (Degrees)	lbs.	kN						
1" Thru 2" (GB/T3091, SCH 40 Pipe (GB/T3091, EN10255H, or JISG3454)		Lateral	30°-44° 45°-59° 60°-74° 75°-90°	1270 1800 2200 2460	(5.64) (9.07) (10.89) (12.18)						
	ru ³ / ₈ " Thick tural Steel	Lateral & Longitudinal	30°-44° 45°-59° 60°-74° 75°-90°	900 1280 1570 1750	(4.00) (5.69) (6.98) (7.78)						
Strut	12 Gauge Channel 1 & 1201	Lateral & Longitudinal	30°-44° 45°-59° 60°-74° 75°-90°	1070 1440 1740 1940	(4.75) (6.40) (7.73) (8.62)						
When governed b	y NFPA13 2019 or late	er, multiply FM appro	ved loads by 0.682	2.							

Brace: 1" Thru 2" SCH40 Pipe (GB/T3091, EN10255H, or JISG3454)										
	Size	Brace Angle	Longit		Wt. Each					
SCH 10, 40 & Flow Pipe		From Vertical (Degrees)	lbs.	kN	lbs.	kg				
2	(50)	30°-44° 45°-59° 60°-74° 75°-90°	1370 1930 2370 2810	(6.09) (8.58) (10.54) (12.49)	2.60	(1.18)				
21/2	(65)	30°-44° 45°-59° 60°-74° 75°-90°	1500 2120 2600 2900	(6.67) (9.43) (11.56) (12.89)	2.77	(1.26)				
3	(80)	30°-44° 45°-59° 60°-74° 75°-90°	1370 1930 2370 2810	(6.09) (8.58) (10.54) (12.49)	3.00	(1.36)				
31/2	(90)	30°-44° 45°-59° 60°-74° 75°-90°	1370 1930 2370 2810	(6.09) (8.58) (10.54) (12.49)	3.13	(1.42)				
4	(100)	30°-44° 45°-59° 60°-74° 75°-90°	1370 1930 2370 2810	(6.09) (8.58) (10.54) (12.49)	3.30	(1.50)				
5	(125)	30°-44° 45°-59° 60°-74° 75°-90°	1370 1930 2370 2810	(6.09) (8.58) (10.54) (12.49)	4.57	(2.07)				
6	(150)	30°-44° 45°-59° 60°-74° 75°-90°	1410 2000 2450 2730	(6.27) (8.89) (10.89) (12.14)	5.42	(2.46)				
8	(200)	30°-44° 45°-59° 60°-74° 75°-90°	1320 1870 2290 2550	(5.87) (8.31) (10.18) (11.34)	8.52	(3.86)				
When by 0.6		d by NFPA13 20	119 or late	r, multiply	FM approv	ed loads				

FM Maximum Design Load

Strut					PHD Stru	t Channe	el Maximur	n Horiz	ontal Load	90° Fro	m Vertica	al			
Fig. #		r			00		200			300					
rig.#		ľ	1/1 -		Max	lbs.	kN		Max	lbs.	kN		Max	lbs.	kN
1001	0.580	(14.73)		58"	(1473.2)	4670	(20.77)	116"	(2946.4)	1165	(5.18)	174"	(4419.6)	518	(2.30)
1201	0.297	(7.54)		29"	(736.6)	3260	(14.50)	59"	(1498.6)	785	(3.49)	89"	(2260.6)	345	(1.53)





44018 Columbiana-Waterford Road Columbiana, Ohio 44408-9481 Phone: 800-321-2736 • 330-482-9256 Fax: 330-482-2763 Web: www.phd-mfg.com

FIG. 031 CLAMPING PIPE ATTACHMENT

Pipe Braced: 2", 2 1/2", 3", 3 1/2", 4", 5", 6", 8"

Bracing: 1" thru 2" SCH 40 pipe, structural steel, and PHD 12 gauge strut channel (1001 & 1201)

Function: Designed for bracing pipe against sway and seismic disturbance. Versatile design allows for attachment at any angle and the ability to be used in a lateral or longitudinal bracing configuration. The pipe attachment component of a sway brace

system used in conjunction with a PHD Manufacturing structural attachment fitting and joined together with a bracing element forming a complete sway brace assembly. Sway brace assemblies are intended to be installed in accordance with

NFPA 13 and the manufacturer's installation instructions. Underwriters Laboratories listed for US and Canada

Approvals: Factory Mutual approved

Listed for use with PHD sway brace components only


Material: Ductile Iron and Low Carbon Steel

Place attachment around pipe to be braced, positioning brace attachment as needed, then tighten clamping bolts and nuts Installation:

finger tight. Insert brace component into fitting against back of jaw. Tighten set screw finger tight, adjust brace angle as needed, then tighten set screw until hex head breaks off. Then evenly torque clamping bolts until hex portion of clamping

nuts break off.





Longitudinal	

			-							
UL Maximum Design Loads										
Pipe Sizes 2" thru 8" SCH 10 & 40 (3 1/2 SCH 40 only) Lateral & Longitudinal Assemblies										
Brace Member	Member Thickness	Member Length	Max. Design Load							
1" Thru 2" Pipe	SCH 40	Refer to NFPA13	1370							
Structural Steel	1/4" to 3/8" thick	Refer to NFPA13	1370							
1001 Series Strut	12 Ga.	See Chart Below	1370							
1201 Series Strut	12 Ga	See Chart Below	1370							

	FM Maximum Design Loads										
				able Hori nstallatio							
		Pipe	Brac	e Angle	From Ve	rtical	Brace				
Orientation	Pipe Size	Schedule	30°-44°	45°-59°	60°-74°	75°-90°	Member				
Lateral	2, 2 1/2, 3, 3 1/2, 4, 5, 6, 8	LW, 10, 40	1270	1800	2200	2460	1" to 2" Schedule 40 Pipe				
Longitudinal	2	LW, 10, 40	1370	1930	2370	2810	1" to 2" Schedule 40 Pipe				
Longitudinal	2 1/2	LW, 10, 40	1500	2120	2600	2900	1" to 2" Schedule 40 Pipe				
Longitudinal	3, 3 1/2, 4	LW, 10, 40	1370	1930	2370	2810	1" to 2" Schedule 40 Pipe				
Longitudinal	5, 6	LW, 10, 40	1410	2000	2450	2730	1" to 2" Schedule 40 Pipe				
Longitudinal	8	LW, 10, 40	1320	1870	2290	2550	1" to 2" Schedule 40 Pipe				
Lateral or Longitudinal	2, 2 1/2, 3, 3 1/2, 4, 5, 6, 8	LW, 10, 40	900	1280	1570	1750	1/4" to 3/8" Thick Structural Steel				
Lateral or Longitudinal	2, 2 1/2, 3, 3 1/2, 4, 5, 6, 8	LW, 10, 40	1070	1440	1740	1940	1001 & 1201 Strut				
7	When governed by NFPA13	2019 or late	r, multipl	v FM apı	proved lo	ads by 0.0	682.				

NOTE: LW above refers to FM Approved Lightwall pipe, commonly referred to as Schedule 7. These ratings may also be applied to EN10220 and GB/T 8163 pipe. Schedule 10 above may be applied to GB/T 3091, GB/T 3092, EN 10255 M and H, JIS G3452. Schedule 40 above may be applied to GB/T3091, EN10255H or JISG3454 brace pipe.

I	Strut		Max. Horizontal Load (lbs.) 90° From Vertical								
	Fig. #	r	1/r =	100		20	00	300			
	1001	0.580		58"	4670	116"	1165	174"	518		
	1201	0.297		29"	3260	59"	785	89"	345		

NOTE: Use NFPA13 table "Allowable Horizontal Load on Brace Assemblies Based on the Weakest Component of the Brace Assembly" reduction factors for maximum loads at varying angles. Refer to www.phd-mfg.com regarding further strut channel details